

Questions & Answers
Country Store (former)
54768-5304-81-A
03-09-548743

QUESTION: 1) I was working on this bid and noticed that there may be an error. It says that the volume to be excavated is 1200 cubic yards AND that the excavation measurements are approximately 30'x40'x12'. These measurements equal only about 534 cubic yards, which is significantly less than 1200 cubic yards. Despite this, should the bids assume 1200 cubic yards?

2) Also, the groundwater monitoring part of the bid says to analyze samples using EPA method 8260. Is this to be VOC or PVOC?

Answer: 1) The volume to be excavated will be approximately 540 cubic yards. Please use this figure when calculating your bid.

2) Analyze samples for VOC's.